



**Brushy Creek Water Supply Corporation**  
P. O. Box 168 249 An Co Rd 432  
Montalba, TX 75853-0168  
903-549-2488 phone 903-549-2483 fax  
[www.brushycreekwsc.org](http://www.brushycreekwsc.org)  
[brushycreekwsc@gmail.com](mailto:brushycreekwsc@gmail.com)

**Mandatory Language for Public Notice**

**Triggered Source Monitoring and Reporting Violation: Groundwater Rule**

Brushy Creek WSC – PWS 0010036 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the groundwater system during December / 2017. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active groundwater well source. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

**What should I do?**

There is nothing you need to do at this time.

**What is being done?**

Collected required additional samples.

For more information, please contact Troy Harbison at 903-549-2488 or P O Box 168 Montalba, TX 75853.

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. \**